



IOWA DEPARTMENT OF NATURAL RESOURCES
AIR QUALITY BUREAU

Initial Notification for Compression Ignition Engines^a

NESHAP for Reciprocating Internal Combustion Engines
40 Code of Federal Regulations (CFR) 63.6580 – 63.6675 (Subpart ZZZZ)

412

REC'D

SEP 02 2010

APCO

Facility Information

Name of Firm/Company		Facility Name (if different)		Facility Number (if known)	
Hershe Casino		Same			
Equipment Location - Street		City	State	Zip	
2701 23RD AVE		Council Bluffs	IA	51501	
Mailing Address (if different)		City	State	Zip	
Same					
Person to Contact		Phone number		Email (if available)	
PETER PERSON		712-396-3701		PPERSON@HARREATHS.COM	

This facility is a (please choose one):

- ☐ Major source: potential or actual emissions greater than 10 tons of any single hazardous air pollutant (HAP) or 25 tons of a combination of HAP
- ☒ Area source: potential and actual emissions below major source levels

Identification of Standard

- ☒ Yes, this facility is subject to 40 CFR Part 63, Subpart ZZZZ, National Emission Standards for Hazardous Air Pollutants for Reciprocating Internal Combustion Engines (RICE NESHAP):

^a This is an example of the type of information that must be submitted to fulfill the Initial Notification requirement of 40 CFR 63, Subpart ZZZZ. You may submit the information in another form or format, or you may use this form.

Engine Data

Emission Unit Number	Emission Unit Description	Is this an emergency engine?	Construction Date	Engine Model Year	Brake Horsepower (bhp)
	800 kW CAT GENERATOR	Not Emergency	4/2003	3412 2003	1180


Existing units: Initial notifications are required to be submitted by August 31, 2010 for the following:

- Area sources: Non-emergency engines > 300 bhp, installed before June 12, 2006
Major sources: Non-emergency engines > 500 bhp, installed before December 19, 2002, and
Non-emergency engines > 100 and ≤ 500 bhp, installed before June 12, 2006

New units: Initial notifications are required to be submitted within 120 days of startup for the following:

- Major sources: All engines > 500 bhp installed on or after December 19, 2002

Signature

Responsible Official Certification			
<input checked="" type="checkbox"/>	I certify the truth, accuracy, and completeness of this notification.		
Responsible Official Name	Responsible Official Signature	Date	
TEE PERSON		8/31/10	

Submit this notification to the following agencies:

- Director, Air and Waste Management Division, U.S. Environmental Protection Agency, 901 N. 5th Street, Kansas City, KS 66101
- NESHAP Coordinator, Iowa Department of Natural Resources, 7900 Hickman, Suite 1; Windsor Heights, IA, 50324
- If the facility is located in either Linn County or Polk County, this notification shall also be submitted to the appropriate county office:

Polk County Public Works – Air Quality Division
5885 NE 14th Street; Des Moines, IA 50313

Linn County Public Health - Air Quality Division
501 13th Street NW; Cedar Rapids, IA 52405



FACSIMILE

REC'D

SEP 02 2010

APCO

TO: Eric Sturm

FROM: Pete Ryerson

**COMPANY: U.S. Environmental Protection Agency
Air & Waste Management Division**

DATE: 9/1/2010

FAX: 913-551-7066

(712) 396-3701 Office

(712) 329-6196 Fax

(402) 619-0962 Cell

Number of Pages (Including Cover Sheet): 3

If you do not receive all pages, please call back as soon as possible.

Pete Ryerson
Facilities & EVS Manager

The information contained in this facsimile is privileged and confidential and intended only for the use of the individual or entity named above. If the reader of this message is not the intended recipient, you are hereby notified that any dissemination, distribution or copying of this communication is strictly prohibited. If you have received this communication in error, address via the US Postal Service. Thank you.